

STATION HEADQUARTER, NAGROTA

1252/STN/FF/Q

14 Oct 19

TO WHOM SO EVER IT MAY CONCERN

1. This is certify that the management of Army Public School, Nagrota having Ground+2 floor school building located at Nagrota Military Station, have provided for the required fire Protection of the School Building and was inspected today and fire risks observed were of very low category and evacuation in case of emergency cannot be a problem.

2. Station Headquarters, Nagrota has 'NO OBJECTION' to the above school as it is protected by fire fighting appliances.

• Hydrant system with

Main Pump - 01 Nos

• Fire Extinguishers

14 Kg capacity CO2 Type Fire Extinguishers	-	05 Nos
4 Kg capacity CO2 Type Fire Extinguishers	-	10 Nos
1 Kg capacity CO2 Type Fire Extinguishers	-	06 Nos
2 Kg capacity CO2 Type Fire Extinguishers	-	02 Nos
6 Kg capacity CO2 Type Fire Extinguishers	-	01 Nos
Fire Beaters	-	03 Nos
Fire Hooks	-	02 Nos
Buckets(Water)	-	03 Nos
Buckets(Sand)	-	03 Nos

3. All Fire equipments installed shall be maintained in working order through out the validity period of this certificate.

4. This certificate is being issued as per CBSE guidelines and is valid till **31 Mar 2020**.



(US Kandil)
Brig
Stn Cdr

**Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu**

**The Principal
Army Public School
Kandoli Nagrota
Jammu**

No: JDJF&ES/FP/ 1471

Dated: 6.03.2020

Sub: Provisional Fire Safety Certificate.

Ref: Your Letter No.APSN/Affln. Gen/08 dated: 04.12.2019.

Dear Sir,

The spot inspection of the above noted School has been got carried out by the inspecting officer of this department. The detailed report of which is as under:-

LOCATION / ACCESSIBILITY:

The school building is situated at Kandoli Nagrota, Jammu. The site is about 08 km away from Fire & Emergency Station City Jammu and is approachable for fire tenders in case of any emergency.

DETAIL OF BUILDING:

The school is triple storied.

EXISTING FIRE FIGHTING SYSTEM:

At present 16 numbers ABC (DCP) Type Fire Extinguishers of 04 kg. capacity each and 09 Nos. of CO₂ Type Fire Extinguishers of 9.5 kg capacity each are provided in the school premises.


Presently there are sixteen number Syntax water storage tanks of 2000 Ltrs. capacity are available in the school premises.

FIRST AID FIRE FIGHTING SYSTEM FOR IMPLEMENTATION-ESSENTIAL REQUIREMENT:

- I) All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
- II) Hose Reel Hoses as per BIS specifications connected with the terrace tank of 5000 Ltrs. capacity should be provided in the School building. The Hose Reel Hose should be kept at such a place where from every nook and corner of each floor of the building are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near underground water storage tank not less than 10 KL capacity with dual electric supply for feeding the terrace tank.
- III) No Hazardous material should be kept inside or outside of the School premises (especially **LPG cylinder, Petrol and Diesel** etc.).
- IV) All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
- V) The corridor of the building shall not be used for any kind of storage.
- VI) One window of each class-room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
- VII) All the electric installations should be concealed conduit type. No naked or loose wiring should be allowed in the School premises.
- VIII) Telephone numbers of nearest Fire & Emergency Stations should be displayed.
- IX) Fire fighting system installed in the School building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the School building.
- X) The management of the School shall be wholly and solely responsible for keeping the fire fighting system of the School in working condition 24x7 to face any eventuality.

The management can proceed ahead for operation provisionally subject to implementation of above said recommendations in letter and spirit forthwith and report this office accordingly for issuance of Final Fire Safety Certificate. The validity of this letter shall remain in force for one year only.

Yours Sincerely



**Joint Director
Fire & Emergency Services
Jammu Range, Jammu**